



issued by an Accredited Testing Laboratory

Marina C Andersson Fire Research +46 10 516 52 92 marinac.andersson@sp.se Date Reference 2015-05-27 5P02939-3

Page 1 (3)



Tikkurila Drytech AB Box 27 642 21 FLEN

Reaction to fire classification report

1 Introduction

This classification report defines the classification assigned to the product "Acoustics" in accordance with the procedure given in EN 13501-1:2007+A1:2009.

2 Details of classified product

2.1 General

The product "Acoustics" is defined as an anti-condensation coating. Its classification is valid for end use application as surface finish on steel.

2.2 Product description

The product, Acoustics, is fully described.

According to the client:

Noise damping coating called "Acoustics", consisting of water based styrene-acrylic resin and perlite. Painted on a galvanized steel sheet with a nominal thickness of 0.9 mm and a nominal density of 7.2 g/cm³.

The amount of paint on the galvanized sheet is 1.2 kg/m² (0.6 kg/m² dry basis). The paint has a nominal density of 1.3 g/cm³.

3 Test reports & test results in support of classification

3.1 Test reports

This classification is based on test reports listed below:

Name of laboratory	Name of sponsor	Test report ref no	Accredited test method
SP	Tikkurila Drytech AB	5P02939-01	EN ISO 1716
SP	Tikkurila Drytech AB	5P02939-2	EN 13823

SP Technical Research Institute of Sweden

3.2 Test results

Test method	Parameter	Parameter Number of tests		Results		
			Continuous parameter mean (m)	Compliance with parameters		
EN 13823		3				
	$FIGRA_{0,2MJ}$ (W/s)		84	Compliant		
	$FIGRA_{0,4MJ}$ (W/s)		62	Compliant		
	LFS < edge		(-)	Compliant		
	THR_{600s} , (MJ)		0.9	Compliant		
	$SMOGRA$, (m^2/s^2)		6	Compliant		
	TSP_{600s} , (m ²)		38	Compliant		
	Flaming droplets/particles		(-)	No flaming droplets/particles		
EN ISO 1716		3				
	$PCS (MJ/m^2) (2)$		3.99	Compliant		
	<i>PCS</i> (MJ/kg) (4)		0.56	Compliant		

^{(-):} not applicable

4 Classification and field of application

4.1 Reference and direct field of application

This classification has been carried out in accordance with clause 11 and 15 of EN 13501-1:2007+A1:2009.

4.2 Classification

The product called "Acoustics" in relation to its reaction to fire behaviour is classified:

A2

The additional classification in relation to smoke production is:

s1

The additional classification in relation to flaming particles/droplets is:

d0

^{(2):} the parameter for the product when applied on steel (external non-substantial component)

^{(4):} the parameter for the combination as a whole when the product is applied on steel

The format of the reaction to fire classification for construction products excluding floorings and linear pipe thermal insulation product is:

Fire Behaviour		Smoke Production			Flaming Droplets	
A2	-	s	1	,	d	0

Reaction to fire classification: A2-s1,d0

4.3 Field of application:

This classification is valid for the following product parameters:

Amount of coating 1.2 kg/m² (0.60 kg/m² dry basis).

Nominal density of coating: 1.3 g/cm³.

This classification is valid for the following end use conditions:

Substrates

 Galvanized metal substrate with a melting point equal or greater than 1000 °C and thickness ≥ 0.9 mm.

The sample was delivered by the client. SP Fire Research was not involved in the sampling procedure.

5 Limitations

This classification document does not represent type approval or certification of the product.

SP Technical Research Institute of Sweden

Fire Research - Fire Dynamics

Marina C Andersson

Performed by

Per Thureson

Examined by