



Marina C Andersson Fire Research +46 10 516 52 92 marinac.andersson@sp.se Date Reference 5P02939-1

Page 1 (3)



Tikkurila Drytech AB Box 27 642 21 FLEN

Reaction to fire classification report

1 Introduction

This classification report defines the classification assigned to the product "Grafo Therm" in accordance with the procedure given in EN 13501-1:2007+A1:2009.

2 Details of classified product

2.1 General

The product "Grafo Therm" is defined as an anti-condensation coating. Its classification is valid for end use application as surface finish on steel.

2.2 Product description

The product, Grafo Therm, is fully described.

According to the client:

Anti-condensation coating called "GrafoTherm", consisting of water based styrene-acrylic resin and perlite. Painted on a galvanized steel sheet with a nominal thickness of 0.9 mm and a nominal density of 7.2 g/cm³.

The amount of paint on the galvanized sheet is 1.0 kg/m² (0.32 kg/m² dry basis). The paint has a nominal density of 1.1 g/cm³.

3 Test reports & test results in support of classification

3.1 Test reports

This classification is based on test reports listed below:

Name of laboratory	Name of sponsor	Test report ref no	Accredited test method	
SP	Tikkurila Drytech AB	5P02939-01	EN ISO 1716	
SP	Tikkurila Drytech AB	5P02939	EN 13823	

SP Technical Research Institute of Sweden



3.2 Test results

Test method	Parameter	Number of tests	Results		
			Continuous parameter mean (m)	Compliance with parameters	
EN 13823		3	0		
	$FIGRA_{0.2MJ}$ (W/s)		96	Compliant	
	$FIGRA_{0,4MJ}$ (W/s)		80	Compliant	
	LFS < edge		(-)	Compliant	
	THR_{600s} , (MJ)		0.9	Compliant	
	$SMOGRA$, (m^2/s^2)		7	Compliant	
	TSP_{600s} , (m ²)		43	Compliant	
	Flaming droplets/particles		(-)	No flaming droplets/particles	
EN ISO 1716		3			
	$PCS (MJ/m^2) (2)$		3.46	Compliant	
	<i>PCS</i> (MJ/kg) (4)		0.51	Compliant	

^{(-):} not applicable

4 Classification and field of application

4.1 Reference and direct field of application

This classification has been carried out in accordance with clause 11 and 15 of EN 13501-1:2007+A1:2009.

4.2 Classification

The product called "Grafo Therm" in relation to its reaction to fire behaviour is classified:

A2

The additional classification in relation to smoke production is:

s1

The additional classification in relation to flaming particles/droplets is:

d0

^{(2):} the parameter for the product when applied on steel (external non-substantial component)

^{(4):} the parameter for the combination as a whole when the product is applied on steel



The format of the reaction to fire classification for construction products excluding floorings and linear pipe thermal insulation product is:

Fire Behaviour		Smoke Production			Flaming Droplets	
A2	-	s	1	,	d	0

Reaction to fire classification: A2-s1,d0

4.3 Field of application:

This classification is valid for the following product parameters:

Amount of coating 1.0 kg/m² (0.32 kg/m² dry basis).

Nominal density of coating: 1.1 g/cm³.

This classification is valid for the following end use conditions:

Substrates

• Galvanized metal substrate with a melting point equal or greater than 1000 °C and thickness ≥ 0.9 mm.

The sample was delivered by the client. SP Fire Research was not involved in the sampling procedure.

5 Limitations

This classification document does not represent type approval or certification of the product.

SP Technical Research Institute of Sweden

Fire Research - Fire Dynamics

Marina C Andersson

Performed by

Per Thuresor